

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7610-1197:100

Page 1 of 1

**CATEGORY:** Misc. Accessories

**LISTEE:** ITW Ramset/Red Head, 1300 N. Michael Dr., Wooddale IL 60191  
Contact: Chris Lavine (630) 350-0370 FAX (630) 350-0370\*

**DESIGN:** Models S12, S34, S38 and S58 self-drilling concrete anchors; Models J12, J34, J38 and J58 non-drilling concrete anchors; Models JS, JS34, JS38 and JS58 stud anchors; Models WS3822, WS3830, WS3836, WS3850, WS1226, WS1242, WS1252, WS5833, WS5850, WS5870, WS3442, WS3462 and WS3484 Trubolt wedge anchors; Models HN1222, HN1230, HN5822, HN5842, HN5860, HN3424, HN3440 and HN3456 Dynabolt sleeve anchors; and Models RM38, RM12, RM58 and RM34 Multi-set II anchors. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, catalog number, size and UL/FM label.

**APPROVAL:** Listed as anchor attachments for automatic fire sprinkler hangers.

**NOTE:** Formerly 7545-1197:100 and 7777-1197:100

\*Rev. 06-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**